

BREWERTON ELEMENTARY

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
1 BDFME	1/17/2025 05:39	1/24/2025 10:51	70333681001	Lead	<1.0	5	ug/L
2 BDFMEBF	1/17/2025 05:39	1/24/2025 11:01	70333681002	Lead	<1.0	5	ug/L
3 BTRSF	1/17/2025 05:41	1/24/2025 11:05	70333681003	Lead	1.2	5	ug/L
4 BKSF1	1/17/2025 05:44	1/24/2025 11:07	70333681004	Lead	5.2	5	ug/L
5 BKSF2	1/17/2025 05:44	1/24/2025 11:08	70333681005	Lead	1.0	5	ug/L
6 BSF206	1/17/2025 05:46	1/24/2025 11:10	70333681006	Lead	1.1	5	ug/L
7 BDFX205	1/17/2025 05:48	1/24/2025 11:12	70333681007	Lead	<1.0	5	ug/L
8 BDFBFX205	1/17/2025 05:48	1/24/2025 11:13	70333681008	Lead	<1.0	5	ug/L
9 BSF205	1/17/2025 05:48	1/24/2025 11:15	70333681009	Lead	<1.0	5	ug/L
10 BSF203	1/17/2025 05:50	1/24/2025 11:19	70333681010	Lead	<1.0	5	ug/L
11 BSF201	1/17/2025 05:53	1/24/2025 11:21	70333681011	Lead	4.9	5	ug/L
12 BSF202	1/17/2025 05:54	1/24/2025 11:22	70333681012	Lead	<1.0	5	ug/L
13 BSF211	1/17/2025 05:56	1/24/2025 11:24	70333681013	Lead	1.0	5	ug/L
14 BSF216	1/17/2025 05:58	1/24/2025 11:26	70333681014	Lead	2.4	5	ug/L
15 BSF218	1/17/2025 05:59	1/24/2025 11:27	70333681015	Lead	<1.0	5	ug/L
16 BSF230	1/17/2025 06:01	1/24/2025 11:29	70333681016	Lead	3.5	5	ug/L
17 BSF229	1/17/2025 06:02	1/24/2025 11:30	70333681017	Lead	1.2	5	ug/L
18 BSF222	1/17/2025 06:03	1/24/2025 11:32	70333681018	Lead	<1.0	5	ug/L
19 BSF224	1/17/2025 06:06	1/24/2025 11:39	70333681019	Lead	<1.0	5	ug/L
20 BSF226	1/17/2025 06:07	1/24/2025 11:44	70333681020	Lead	1.1	5	ug/L
21 BSF225	1/17/2025 06:07	1/24/2025 11:48	70333681021	Lead	<1.0	5	ug/L
22 BSF223	1/17/2025 06:08	1/24/2025 11:50	70333681022	Lead	1.4	5	ug/L
23 BSF221	1/17/2025 06:09	1/24/2025 11:52	70333681023	Lead	1.1	5	ug/L
24 BSF219	1/17/2025 06:11	1/24/2025 11:56	70333681024	Lead	2.1	5	ug/L
25 BSF217	1/17/2025 06:13	1/24/2025 11:58	70333681025	Lead	6.4	5	ug/L
26 BDFH217	1/17/2025 06:13	1/24/2025 11:59	70333681026	Lead	<1.0	5	ug/L
27 BDFBF217	1/17/2025 06:13	1/24/2025 12:01	70333681027	Lead	<1.0	5	ug/L
28 BGHDF	1/17/2025 05:23	1/24/2025 12:03	70333681028	Lead	<1.0	5	ug/L
29 BGHDFBF	1/17/2025 05:23	1/24/2025 12:04	70333681029	Lead	<1.0	5	ug/L
30 BSF103	1/17/2025 05:26	1/24/2025 12:06	70333681030	Lead	<1.0	5	ug/L
31 BSF101	1/17/2025 05:28	1/24/2025 12:07	70333681031	Lead	1.9	5	ug/L
32 BSF100	1/17/2025 05:30	1/24/2025 12:09	70333681032	Lead	2.4	5	ug/L
33 BSF102	1/17/2025 05:32	1/24/2025 12:10	70333681033	Lead	<1.0	5	ug/L
34 BSF104	1/17/2025 05:34	1/24/2025 12:15	70333681034	Lead	1.9	5	ug/L
35 BSF106	1/17/2025 05:35	1/24/2025 12:17	70333681035	Lead	<1.0	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb