

HASTINGS MALLORY ELEMENTARY SCHOOL

BOTTLE #	LOCATION	SAMPLE ID	ANALYSIS	NYSDOH ACTION LEVEL	RESULTS
1	HME kitchen sink faucet 1	HKSF1	LEAD	5 ug/l	2.3 ug/l
2	HME kitchen sink faucet 2	HKSF2	LEAD	5 ug/l	<1.0 ug/l
3	HME kitchen sink faucet 3	HKSF3	LEAD	5 ug/l	1.2ug/l
4	HME kitchen sink faucet 4	HKSF4	LEAD	5 ug/l	1.2 ug/l
5	HME drinking fountain by boiler room	HDFBR	LEAD	5 ug/l	<1.0 ug/l
6	HME drinking fountain bottle fill boiler room	HDFBFBR	LEAD	5 ug/l	<1.0 ug/l
7	HME sink faucet teachers break room	HSFTBR	LEAD	5 ug/l	<1.0 ug/l
8	HME drinking fountain gang restroom	HDFGR1	LEAD	5 ug/l	<1.0 ug/l
9	HME bottle fill gang restroom	HBFGGR	LEAD	5 ug/l	<1.0 ug/l
10	HME sink faucet room 14	HSF14	LEAD	5 ug/l	148.0 ug/l
11	HME sink faucet room 15	HSF15	LEAD	5 ug/l	2.7 ug/l
12	HME sink faucet room 17	HSF17	LEAD	5 ug/l	2.4 ug/l
13	HME sink faucet room 18	HSF18	LEAD	5 ug/l	4.0 ug/l
14	HME sink faucet room 19	HSF19	LEAD	5 ug/l	4.0 ug/l
15	HME sink faucet room 20	HSF20	LEAD	5 ug/l	6.7 ug/l
16	HME sink faucet room 21	HSF21	LEAD	5 ug/l	3.9 ug/l
17	HME sink faucet room 22	HSF22	LEAD	5 ug/l	<1.0 ug/l
18	HME sink faucet room 23	HSF23	LEAD	5 ug/l	1.4 ug/l
19	HME sink faucet room 24A	HSF24A	LEAD	5 ug/l	<1.0 ug/l
20	HME Sink faucet room 28 nurse	HSF28N	LEAD	5 ug/l	<1.0 ug/l
21	HME sink faucet room 50	HSF50	LEAD	5 ug/l	<1.0 ug/l
22	HME sink faucet room 49	HSF49	LEAD	5 ug/l	2.9 ug/l
23	HME sink faucet room 48	HSF48	LEAD	5 ug/l	4.6 ug/l
24	HME sink faucet room 47	HSF47	LEAD	5 ug/l	2.0 ug/l

25	HME sink faucet room 46	HSF46	LEAD	5 ug/l	1.2 ug/l
26	HME sink faucet room 45	HSF45	LEAD	5 ug/l	1.9 ug/l
27	HME sink faucet room 44	HSF44	LEAD	5 ug/l	2.2 ug/l
28	HME sink faucet room 43	HSF43	LEAD	5 ug/l	5.2 ug/l
29	HME sink faucet room 42	HSF42	LEAD	5 ug/l	1.4 ug/l
30	HME sink faucet room 41	HSF41	LEAD	5 ug/l	1.1 ug/l
31	HME sink faucet room 40	HSF40	LEAD	5 ug/l	2.9 ug/l
32	HME sink faucet room 39	HSF39	LEAD	5 ug/l	1.6 ug/l
33	HME drinking fountain by gym	HDFG	LEAD	5 ug/l	<1.0 ug/l
34	HME bottle fill by gym	HBFG	LEAD	5 ug/l	<1.0 ug/l
35	HME room 201 sink faucet 1	H201SF1	LEAD	5 ug/l	1.9 ug/l
36	HME room 201 sink faucet 2	H201SF2	LEAD	5 ug/l	3.9 ug/l
37	HME custodial breakroom sink faucet	HCBRSF	LEAD	5 ug/l	<1.0 ug/l
38	HME drinking fountain by 44A	HDFB44A	LEAD	5 ug/l	<1.0 ug/l
39	HM bottle fill by 44A	HBFB44A	LEAD	5 ug/l	<1.0 ug/l