

PVM HIGH SCHOOL

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH	Units
4. P6021	5/1/2025 6:30	5/15/2025 19:20	70352443001	Lead	4	5	ug/L
23. PSFIR1127	5/1/2025 6:33	5/15/2025 19:22	70352443002	Lead	<1.0	5	ug/L
39. PWDFBF1266	5/1/2025 6:35	5/15/2025 19:24	70352443003	Lead	<1.0	5	ug/L
PKSWBSF3= kitchen spray wand by sink faucet 3 This fixture is used to spray out the dishwasher. There is no access by students. A DO NOT DRINK THE WATER SIGN has been posted Location has been remediated.							