

BREWERTON ELEMENTARY SCHOOL					
BOTTLE #	LOCATION	SAMPLE ID	ANALYSIS	NYSDOH ACTION LEVEL	RESULTS
4	Brew kit sink faucet #1	BKSF1	LEAD	5 ug/l	1.9 ug/l
25	Brew sink faucet 217	BSF217	LEAD	5 ug/l	2.4 ug/l